

Certificate of Compliance

This is to certify that

EDGE ANALYTICAL, Inc.,

An Accredited Drinking Water Laboratory,

Certification number 046, has completed the analysis of

QUALITY WATER SERVICES
“Just Squeezed Drinking Water”

on April 30, 2008, according to the IBWA “Appendix A” testing requirements for bottled drinking water. All parameters were found to be in compliance with FDA’s and IBWA’s published Standard of Quality limits for bottled drinking water.

Report signed this 30th day of April, 2008.



Lawrence J. Henderson, Ph.D.
Laboratory Director



EDGE
ANALYTICAL
LABORATORIES



Burlington WA	1620 S Walnut St - 98233
Corporate Office	800.755.9295 • 360.757.1400 • 360.757.1402fax
Bellingham WA	805 Orchard Dr Suite 4 - 98225
Microbiology	360.671.0688 • 360.671.1577fax

April 30, 2008

Page 1 of 1

Bill Cunningham
Quality Water Services
P O Box 829
Ponca City, OK 74601

RE: 08-04859 - IBWA Product Just Squeezed DW

Dear Bill Cunningham,

Your project: IBWA Product Just Squeezed DW, was received on Wednesday April 16, 2008.

The following comments are reported for your project:

Total Recoverable Phenolics testing is not required when the Odor result is less than 3 Threshold Odor Number (TON).
This criteria follows phone conversations with FDA and IBWA on July 16, 2003.

If you have questions please phone me at 800 755-9295.

Respectfully Submitted,

A handwritten signature in black ink, appearing to read "L Henderson", with a long horizontal flourish extending to the right.

Lawrence J Henderson, PhD
Director of Laboratories

Enclosures Data Report



Burlington WA | 1620 S Walnut St - 98233
 Corporate Office | 800.755.9295 • 360.757.1400 • 360.757.1402fax
 Bellingham WA | 805 Orchard Dr Suite 4 - 98225
 Microbiology | 360.671.0688 • 360.671.1577fax



IBWA STANDARD OF QUALITY REPORT

Client Name: Quality Water Services
 P O Box 829
 Ponca City, OK 74601

Reference Number: 08-04859

Project: IBWA Product Just Squeezed D
 Field ID: 3rd Yr IBWA
 Sample Description: Product Just Squeezed Drinking Water
 Sampled By:
 Sample Date: 04/16/2008

Lab Number: 10444
 Report Date: 04/30/2008
 Reviewed By: *[Signature]*

Inorganic Chemicals (IOCs)

GAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	COMMENT
7440-36-0	ANTIMONY	ND	0.006	0.001	mg/L	200.8	
7440-38-2	ARSENIC	ND	0.010	0.001	mg/L	200.8	
7440-39-3	BARIUM	ND	1.0	0.010	mg/L	200.8	
7440-41-7	BERYLLIUM	ND	0.004	0.001	mg/L	200.8	
7440-43-9	CADMIUM	ND	0.005	0.001	mg/L	200.8	
7440-47-3	CHROMIUM	ND	0.05	0.005	mg/L	200.8	
57-12-5	CYANIDE, FREE	ND	0.1	0.040	mg/L	SM4500-CN F	
16984-48-8	FLUORIDE	ND	2.4	0.10	mg/L	300.0	
7439-92-1	LEAD	ND	0.005	0.001	mg/L	200.8	
7439-97-6	MERCURY	ND	0.001	0.0002	mg/L	245.1	
7440-02-0	NICKEL	ND	0.1	0.001	mg/L	200.8	
14797-55-8	NITRATE-N	ND	10	0.10	mg/L	300.0	
14797-65-0	NITRITE-N	ND	1.0	0.10	mg/L	300.0	
E-10128	TOTAL NITRATE/NITRITE	ND	10	0.10	mg/L	300.0	
7782-49-2	SELENIUM	ND	0.010	0.005	mg/L	200.8	
7440-28-0	THALLIUM	ND	0.002	0.001	mg/L	200.8	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
 MRL - Method Reporting Limit.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence Henderson at the above phone number.



Reference Number: 08-04859
Lab Number: 10444
Report Date: 04/30/2008

IBWA STANDARD OF QUALITY REPORT

Page 2 of 7

Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	COMMENT
7429-90-5	ALUMINUM	ND	0.2	0.010	mg/L	200.7	
16887-00-6	CHLORIDE	2.9	250	1	mg/L	300.0	
7440-50-8	COPPER	ND	1.0	0.005	mg/L	200.8	
7439-89-6	IRON	ND	0.3	0.050	mg/L	200.7	
7439-96-5	MANGANESE	ND	0.05	0.005	mg/L	200.8	
7440-22-4	SILVER	ND	0.025	0.010	mg/L	200.8	
14808-79-8	SULFATE	0.9	250	10	mg/L	300.0	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	ND	500	10	mg/L	SM2540 C	
7440-66-6	ZINC	ND	5.0	0.05	mg/L	200.8	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
MRL - Method Reporting Limit.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

IBWA STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	COMMENT
71-55-6	1,1,1 - TRICHLOROETHANE	ND	30	0.4	ug/L	524.2	
79-00-5	1,1,2 - TRICHLOROETHANE	ND	3	0.4	ug/L	524.2	
75-35-4	1,1 - DICHLOROETHYLENE	ND	2	0.4	ug/L	524.2	
120-82-1	1,2,4 - TRICHLOROBENZENE	ND	9	0.4	ug/L	524.2	
107-06-2	1,2 - DICHLOROETHANE	ND	2	0.4	ug/L	524.2	
78-87-5	1,2 - DICHLOROPROPANE	ND	5	0.4	ug/L	524.2	
71-43-2	BENZENE	ND	1	0.4	ug/L	524.2	
56-23-5	CARBON TETRACHLORIDE	ND	5	0.4	ug/L	524.2	
156-59-2	CIS - 1,2 - DICHLOROETHYLENE	ND	70	0.4	ug/L	524.2	
156-60-5	TRANS - 1,2 - DICHLOROETHYLENE	ND	100	0.4	ug/L	524.2	
100-41-4	ETHYLBENZENE	ND	700	0.4	ug/L	524.2	
75-09-2	METHYLENE CHLORIDE (DICHLOROMI	ND	3	0.4	ug/L	524.2	
108-90-7	MONOCHLOROBENZENE	ND	50	0.4	ug/L	524.2	
95-50-1	O - DICHLOROBENZENE	ND	600	0.4	ug/L	524.2	
106-46-7	P - DICHLOROBENZENE	ND	75	0.4	ug/L	524.2	
100-42-5	STYRENE	ND	100	0.4	ug/L	524.2	
127-18-4	TETRACHLOROETHYLENE	ND	1	0.4	ug/L	524.2	
108-88-3	TOLUENE	ND	1000	0.4	ug/L	524.2	
79-01-6	TRICHLOROETHYLENE	ND	1	0.4	ug/L	524.2	
75-01-4	VINYL CHLORIDE	ND	2	0.4	ug/L	524.2	
1330-20-7	XYLENES (TOTAL)	ND	1000	0.4	ug/L	524.2	
75-27-4	BROMODICHLOROMETHANE	ND		0.4	ug/L	524.2	
124-48-1	CHLORODIBROMOMETHANE	ND		0.4	ug/L	524.2	
67-66-3	CHLOROFORM	ND		0.4	ug/L	524.2	
75-25-2	BROMOFORM	ND		0.4	ug/L	524.2	
E-14471	TOTAL TRIHALOMETHANE	ND	10	0.4	ug/L	524.2	
1634-04-4	METHYL TERT-BUTYL ETHER	ND	70	0.4	ug/L	524.2	
91-20-3	NAPHTHALENE	ND	300	0.4	ug/L	524.2	
79-34-5	1,1,1,2,2 - TETRACHLOROETHANE	ND	1	0.4	ug/L	524.2	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.

SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.

MRL - Method Reporting Limit.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

IBWA STANDARD OF QUALITY REPORT

Synthetic Organic Chemicals (SOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	COMMENT
93-72-1	2,4,5 - TP (SILVEX)	ND	10	0.4	ug/L	515.1	
94-75-7	2,4 - D	ND	70	0.2	ug/L	515.1	
15972-60-8	ALACHLOR	ND	2	0.2	ug/L	525.2	
116-06-3	ALDICARB	ND	3	1	ug/L	531.2	
1646-88-4	ALDICARB SULFONE	ND	3	1	ug/L	531.2	
1646-87-3	ALDICARB SULFOXIDE	ND	4	1	ug/L	531.2	
1912-24-9	ATRAZINE	ND	3	0.1	ug/L	525.2	
1563-66-2	CARBOFURAN	ND	40	1	ug/L	531.2	
57-74-9	CHLORDANE	ND	2	0.2	ug/L	525.2	
75-99-0	DALAPON	ND	200	2	ug/L	515.1	
96-12-8	DIBROMOCHLOROPROPANE (DBCP)	ND	0.2	0.04	ug/L	504.1	
88-85-7	DINOSEB	ND	7	0.4	ug/L	515.1	
72-20-8	ENDRIN	ND	2	0.01	ug/L	525.2	
106-93-4	ETHYLENE DIBROMIDE (EDB)	ND	0.05	0.02	ug/L	504.1	
76-44-8	HEPTACHLOR	ND	0.4	0.04	ug/L	525.2	
1024-57-3	HEPTACHLOR EPOXIDE "B"	ND	0.2	0.02	ug/L	525.2	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.2	0.02	ug/L	525.2	
72-43-5	METHOXYCHLOR	ND	40	0.1	ug/L	525.2	
23135-22-0	OXYMAL (VYDATE)	ND	200	1	ug/L	531.2	
87-86-5	PENTACHLOROPHENOL	ND	1	0.04	ug/L	525.2	
1918-02-1	PICLORAM	ND	500	0.2	ug/L	515.1	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCB)	ND	0.5	0.2	ug/L	508.1	
122-34-9	SIMAZINE	ND	4	0.07	ug/L	525.2	
8001-35-2	TOXAPHENE	ND	3	1	ug/L	525.2	
41903-57-5	DIOXIN (2,3,7,8-TETRACHLORODIBENZ)	ND	30	5	pg/L	1613	Analyzed by Pace Analytical
85-00-7	DIQUAT	ND			mg/L	549.2	
145-73-3	ENDOTHALL	ND	100	20	ug/L	548.1	
1071-83-6	GLYPHOSATE	ND	700	10	ug/L	547	
50-32-8	BENZO(A)PYRENE	ND	0.2	0.02	ug/L	525.2	
103-23-1	DI(2-ETHYLHEXYL)-ADIPATE	ND	400	1.32	ug/L	525.2	
117-81-7	DI(2-ETHYLHEXYL)-PHTHALATE	ND	6	0.6	ug/L	525.2	
118-74-1	HEXACHLOROBENZENE	ND	1	0.1	ug/L	525.2	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	50	0.1	ug/L	525.2	
E-10253	TOTAL RECOVERABLE PHENOLICS	NA	1	1	ug/L	420.1	Not Analyzed

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
 MRL - Method Reporting Limit.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Reference Number: 08-04859
Lab Number: 10444
Report Date: 04/30/2008

IBWA STANDARD OF QUALITY REPORT

Page 5 of 7

Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	COMMENT
E-11712	COLOR	ND	5	5	Color Units	SM2120 B	
E-10617	TURBIDITY	0.08		0.05	NTU	180.1	
E-10139	HYDROGEN ION (pH)	7.47	5.0-8.5		pH Units	150.1	
E-11734	ODOR	1	3	1	TON	SM2150	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDR or IBWA.
MRL - Method Reporting Limit.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Reference Number: 08-04859
Lab Number: 10444
Report Date: 04/30/2008

IBWA STANDARD OF QUALITY REPORT

Page 6 of 7

Disinfectants/DBP

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	COMMENT
NA	HAA(5)	ND	0.060	0.001	mg/L	552.2	
15541-45-4	*BROMATE	ND	0.010	0.005	mg/L	300.1	
10049-04-4	*CHLORINE DIOXIDE	ND	0.8	0.1	mg/L	SM4500-CIO2 I	
7758-19-2	*CHLORITE	ND	1.00	0.050	mg/L	300.1	
NA	*CHLOROAMINES TOTAL	ND	4.0	0.05	mg/L	SM4500-CI G	
7782-50-5	CHLORINE	ND	0.1	0.05	mg/L	SM4500-CI G	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
MRL - Method Reporting Limit.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Reference Number: 08-04859
Lab Number: 10444
Report Date: 04/30/2008

IBWA STANDARD OF QUALITY REPORT

Page 7 of 7


Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	COMMENT
12587-46-1	GROSS ALPHA	ND	15	3	pCi/L	900.0	Analyzed by Benchmar Analytics
12587-47-2	GROSS BETA	ND	50	4	pCi/L	900.0	Analyzed by Benchmar Analytics
13982-63-3	RADIUM 226	ND		1	pCi/L	903.1	Analyzed by Benchmar Analytics
	RADIUM 228	ND		1	pCi/L	904.0	Analyzed by Benchmar Analytics
7440-61-1	URANIUM	ND	0.030	0.001	mg/L	200.8	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by EPA, NPDWR or IBWA.
MRL - Method Reporting Limit.
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Burlington WA 1620 S Walnut St - 98233
 Corporate Office 800.755.9295 • 360.757.1400 • 360.757.1402fax
 Bellingham WA 805 Orchard Dr Suite 4 - 98225
 Microbiology 360.671.0688 • 360.671.1577fax



Data Report

Client Name: Quality Water Services
 P O Box 829
 Ponca City, OK 74601

Reference Number: **08-04859**
 Project: IBWA Product Just Squeezed
 Report Date: 4/30/08
 Date Received: 4/16/08
 Peer Review: *[Signature]*

Sample Description: 3rd Yr IBWA - Product Just Squeezed Drinking Water	Sample Date: 4/16/08
Lab Number: 10444	Collected By:

CAS ID#	Parameter	Result	PQL	MDL	Units	DF	Method	Analyzed	Analyst	Batch	Comment
E-10184	ELECTRICAL CONDUCTIVITY	27.8	10		uS/cm	1	SM2510 B	4/16/08	CCN	EC_080418	
7440-23-5	SODIUM	5.78	0.50	0.03	mg/L	1	200.7	4/21/08	BJ	200.7-080421A	
E-11778	HARDNESS	ND	10	0.055	mg CaCO3/L	1	200.7	4/21/08	BJ	200.7-080421A	
7440-70-2	CALCIUM	ND	1	0.017	mg/L	1	200.7	4/21/08	BJ	200.7-080421A	
7439-95-4	MAGNESIUM	ND	1	0.003	mg/L	1	200.7	4/21/08	BJ	200.7-080421A	

Notes:

ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.
 PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.
 D.F. - Dilution Factor

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence Henderson at the above phone number.